

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE



LISTING No. 7300-1483:174 Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Mirtone, 8985 Town Center Parkway, Bradenton, FL 34202
Contact: Jewell Micochero (941) 739-4358 FAX (941) 308-8123

DESIGN: Models MIRBPS6A, MIRBPS10A, MIRBPS6A/230, and MIRBPS10A/230 remote booster power supplies. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 120 V/240 V, 60 Hz, 50 Hz

INSTALLATION: In accordance with listee's printed installation instruction, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating, and UL label.

APPROVAL: Listed as remote booster power supplies for use with listee's separately listed compatible fire alarm control units to extend the notification appliance circuit. Refer to listee's Installation Instruction Manual for details.

XLF: 7300-1591:229

01-02-2005



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 28, 2008**

*Listing Expires **June 30, 2009***

Authorized By: **BEN HO, Chief**
Fire Engineering Division